



Oncor – Temple Area Project ERCOT Independent Review Status Update – Options

Tanzila Ahmed

RPG Meeting
May 14, 2024

Recap – Introduction

- Oncor submitted the Temple Area Project for Regional Planning Group (RPG) review in January 2024
 - This Tier 1 project is estimated to cost \$120.7 million, and filing of Certificate of Convenience and Necessity (CCN) is not required
 - Estimated in-service date is May 2026
 - This project addresses identified thermal violations, provides additional 345-kV sources, further networks transmission facilities, and enhances system reliability in the Temple area in Bell County
- Oncor presented project overview and ERCOT presented study scope for this ERCOT Independent Review (EIR) at the February RPG meeting
 - <https://www.ercot.com/calendar/02122024-RPG-Meeting>
- ERCOT provided status update at the March RPG meeting
 - [https://www.ercot.com/calendar/03182024-RPG-Meeting- -Webex](https://www.ercot.com/calendar/03182024-RPG-Meeting--Webex)

Recap – Preliminary Results of Reliability Assessment – Need Analysis

- ERCOT conducted steady-state load flow analysis for the study base case according to the NERC TPL-001-5.1 and ERCOT Planning Criteria to identify project need

Contingency Category	Voltage Violations	Thermal Violations	Unsolved Power Flow
N-0 (P0)	None	None	None
N-1 (P1, P2-1, P7)	None	None	None
G-1+N-1 (P3)*	None	None	None
X-1+N-1 (P6-2)**	31	5	None

* G-1: Comanche Peak Unit and Panda CC Train


** X-1: Temple Switch, Temple Pecan Creek Switch, Killeen 345/138-kV autotransformers, Seaton and Bell County 138/69-kV transformers (sensitivity provided by TSPs)

Recap – Details of Thermal Overloads Seen in the Reliability Assessment – Need Analysis

Overloaded Element	Worst Contingency (N-1-1)	Length (miles)	Worst Overload (%)
Temple Pecan Creek SW – Temple SW 138-kV Line	Temple SW 345/138-kV Autotransformer + Temple Pecan Creek – Temple Elm Creek 138-kV DCKT	4.4	122.3
Belton - Belton Southwest 138-kV Line	Killeen SW 345/138-kV Autotransformer 2 + Killeen SW 345/138-kV Autotransformer 1	2.0	115.5
Belton Southwest – Harker Heights South 138-kV Line	Killeen SW 345/138-kV Autotransformer 2 + Killeen SW 345/138-kV Autotransformer 1	10.3	103.8
Temple Pecan Creek SW 345/138-kV Autotransformer	Temple SW 345/138-kV Autotransformer + Knob Creek SW – Salado SW 345-kV Line	0.0	103.5
Temple North 2 – Pepper Creek SW 138-kV Line	Killeen SW 345/138-kV Autotransformer 2 + Temple North 2 – Temple Elm Creek 138-kV Line	2.2	103.3
Temple SW 345/138-kV Autotransformer	Temple Pecan Creek SW 345/138-kV Autotransformer + Knob Creek SW – Salado SW 345-kV Line	5.1	102.8
Belton - Nolanville 138-kV Line	Killeen SW 345/138-kV Autotransformer 2 + Killeen SW 345/138-kV Autotransformer 1	0.0	101.8

(Map on next slide)

Recap – Study Area Map with Violations Seen by ERCOT



Project Need Seen by ERCOT	
	Thermal Violation
	Aging Infrastructures
	TSP Criteria Violation

Voltage Legend	
	69-kV
	115-kV
	138-kV
	345-kV

Line Legend	
	Existing Line
	Proposed New Line
	Upgrade Existing Line
	Convert Existing Line
	Retire Existing Line

Substation Legend	
	Existing Substation
	New/Convert Substation
	New Transformer



Status Update


- Project Evaluation
 - Alternate options identified
 - Reliability analysis all option
 - N-1
 - G-1+N-1
 - G-1: Comanche Peak Unit 1
 - G-1: Panda CC Train 1
 - X-1+N-1
 - X-1: Temple Switch, Temple Pecan Creek Switch, Killeen 345/138-kV autotransformers
 - X-1: Seaton and Bell County 138/69-kV autotransformers (sensitivity provided by TSPs)
 - Short-listed option identified
 - Long-term load serving capability assessment

Option 1 – Proposed Project by Oncor

- Install a second 345/138-kV autotransformer at the existing Temple Pecan Creek substation with 600 MVA rating and loop in the existing Temple SW – Belfalls 345-kV transmission line into Temple Pecan Creek substation
- Install a second 345/138-kV autotransformer at the existing Temple SW substation with 600 MVA rating, and rebuild the existing Temple SW substation with 11 345-kV and 16 138-kV breakers in breaker-and-a-half arrangements, and remove the 138/69-kV autotransformer
- Construct a second circuit to the existing Temple Pecan Creek – Temple SW 138-kV transmission line with a minimum ratings of 486 MVA, 4.4-mile
- Construct a new Boggy Creek 138/69-kV substation approximately 3.58-mile south of the existing Temple 138-kV substation. Relocated the existing 138/69-kV autotransformer from Temple SW to the new Boggy Creek substation, install seven 138-kV breakers in breaker-and-a-half arrangement, and install two 69-kV breakers in single bus arrangement
- Loop in the existing Bell County SW – Temple SW 138-kV transmission line into the new Boggy Creek substation and loop in the existing Taylor SW – Temple SW 138-kV transmission line into the new Boggy Creek substation
- Construct a new Boggy Creek – Minerva 69-kV transmission line with a minimum ratings of 197, approximately 5.0-mile
 - From the Bobby Creek on the vacant sides of the existing double circuit capable structures of Taylor SW – Temple SW and Poague – Seaton 69-kV transmission lines and connecting the existing Minerva at STR 3/5. Disconnecting the existing Temple SW – Minerva 69-kV transmission line at STR 3/5
- Upgrade the existing Temple Pecan Creek – Temple Elm Creek 138-kV double-circuit transmission line with a minimum ratings of 486 MVA, 5.1-mile per circuit

(Map on next slide)

Option 1 Map



Project Need Seen by ERCOT	
	Thermal Violation
	Aging Infrastructures
	TSP Criteria Violation

Voltage Legend	
	69-kV
	115-kV
	138-kV
	345-kV

Line Legend	
	Existing Line
	Proposed New Line
	Upgrade Existing Line
	Convert Existing Line
	Retire Existing Line

Substation Legend	
	Existing Substation
	New/Convert Substation
	New Transformer




Option 2 – Similar to Option 1

- Install a second 345/138-kV autotransformer at the existing Temple Pecan Creek substation with 600 MVA rating and loop in the existing Temple SW – Belfalls 345-kV transmission line into Temple Pecan Creek substation
- Install a second 345/138-kV autotransformer at the existing Temple SW substation with 600 MVA rating, and rebuild the existing Temple SW substation with 11 345-kV and 16 138-kV breakers in breaker-and-a-half arrangements, and remove the 138/69-kV autotransformer
- Construct a second circuit to the existing Temple Pecan Creek – Temple SW 138-kV transmission line with a minimum ratings of 486 MVA, 4.4-mile
- Construct a new Boggy Creek 138/69-kV substation approximately 3.58-mile south of the existing Temple 138-kV substation. Relocated the existing 138/69-kV autotransformer from Temple SW to the new Boggy Creek substation, install seven 138-kV breakers in breaker-and-a-half arrangement, and install two 69-kV breakers in single bus arrangement
- Loop in the existing Bell County SW – Temple SW 138-kV transmission line into the new Boggy Creek substation and loop in the existing Taylor SW – Temple SW 138-kV transmission line into the new Boggy Creek substation
- Construct a new Boggy Creek – Minerva 69-kV transmission line with a minimum ratings of 197, approximately 5.0-mile
 - From the Bobby Creek on the vacant sides of the existing double circuit capable structures of Taylor SW – Temple SW and Poague – Seaton 69-kV transmission lines and connecting the existing Minerva at STR 3/5. Disconnecting the existing Temple SW – Minerva 69-kV transmission line at STR 3/5

Option 2 – Continued

- Upgrade the existing Belton – Belton Southwest – Harker Heights South 138-kV transmission lines with a minimum ratings of 486 MVA, 20.6-mile
- Upgrade the existing Belton – Nolanville 138-kV transmission lines with a minimum ratings of 486 MVA, 2.1-mile
- Upgrade the existing Temple North-2 – Pepper Creek 138-kV transmission line with a minimum ratings of 486 MVA, 2.2-mile
- Install two blocks of 18.4 MVAR capacitor banks at each of the existing Killeen Taft St., Killeen, and Killeen Ft. Hood 138-kV substations

Option 2 Map



Project Need Seen by ERCOT	
	Thermal Violation
	Aging Infrastructures
	TSP Criteria Violation

Voltage Legend	
	69-kV
	115-kV
	138-kV
	345-kV

Line Legend	
	Existing Line
	Proposed New Line
	Upgrade Existing Line
	Convert Existing Line
	Retire Existing Line

Substation Legend	
	Existing Substation
	New/Convert Substation
	New Transformer



Option 3 – Similar to Option 2


- Install a second 345/138-kV autotransformer at the existing Temple Pecan Creek substation with 600 MVA rating and loop in the existing Temple SW – Belfalls 345-kV transmission line into Temple Pecan Creek substation
- Install a second 345/138-kV autotransformer at the existing Temple SW substation with 600 MVA rating, and rebuild the existing Temple SW substation with 11 345-kV and 16 138-kV breakers in breaker-and-a-half arrangements, and remove the 138/69-kV autotransformer
- Construct a second circuit to the existing Temple Pecan Creek – Temple SW 138-kV transmission line with a minimum ratings of 486 MVA, 4.4-mile
- Construct a new Boggy Creek 138/69-kV substation approximately 3.58-mile south of the existing Temple 138-kV substation. Relocated the existing 138/69-kV autotransformer from Temple SW to the new Boggy Creek substation, install seven 138-kV breakers in breaker-and-a-half arrangement, and install two 69-kV breakers in single bus arrangement
- Loop in the existing Bell County SW – Temple SW 138-kV transmission line into the new Boggy Creek substation and loop in the existing Taylor SW – Temple SW 138-kV transmission line into the new Boggy Creek substation
- Construct a new Boggy Creek – Minerva 69-kV transmission line with a minimum ratings of 197, approximately 5.0-mile
 - From the Bobby Creek on the vacant sides of the existing double circuit capable structures of Taylor SW – Temple SW and Poague – Seaton 69-kV transmission lines and connecting the existing Minerva at STR 3/5. Disconnecting the existing Temple SW – Minerva 69-kV transmission line at STR 3/5

(Continued on next slide)

Option 3 – Continued

- Upgrade the existing Belton – Belton Southwest – Harker Heights South 138-kV transmission lines with a minimum ratings of 486 MVA, 20.6-mile
- Upgrade the existing Belton – Nolanville 138-kV transmission lines with a minimum ratings of 486 MVA, 2.1-mile
- Upgrade the existing Temple North-2 – Pepper Creek 138-kV transmission line with a minimum ratings of 486 MVA, 2.2-mile
- Install two blocks of 18.4 MVAR capacitor banks at each of the existing Killeen Taft St., Killeen, and Killeen Ft. Hood 138-kV substations
- Upgrade the existing Nolanville – Harker Heights – Killeen Taft Street – Killeen Elm 138-kV transmission lines with a minimum ratings of 486 MVA, 11.3-mile
- Upgrade the existing Temple Elm Creek – Temple North 138-kV double-circuit transmission line with a minimum ratings of 486 MVA, 0.5-mile per-circuit
- Install a second 138/69-kV autotransformer at the existing Seaton 138/69-kV substation with 100 MVA rating
- Upgrade the existing Seaton – Poague – Temple Taylor Valley 69-kV transmission lines, 138-kV capable but operational at 69-kV, with a minimum ratings of 197 MVA, 3.4-mile
- **NOTE:** A sensitivity was tested on Option 3 that included a second circuit to the existing Knob Creek – Salado SW 345-kV transmission line with a minimum ratings of 1912 MVA, 13.8-mile

Option 3 Map



Project Need Seen by ERCOT	
	Thermal Violation
	Aging Infrastructures
	TSP Criteria Violation

Voltage Legend	
	69-kV
	115-kV
	138-kV
	345-kV

Line Legend	
	Existing Line
	Proposed New Line
	Upgrade Existing Line
	Convert Existing Line
	Retire Existing Line

Substation Legend	
	Existing Substation
	New/Convert Substation
	New Transformer



Option 4 – Similar to Option 3, without the 69-kV Upgrade & Separating 138/345-kV DCKT


- Install a second 345/138-kV autotransformer at the existing Temple Pecan Creek substation with 600 MVA rating and loop in the existing Temple SW – Belfalls 345-kV transmission line into Temple Pecan Creek substation
- Install a second 345/138-kV autotransformer at the existing Temple SW substation with 600 MVA rating, and rebuild the existing Temple SW substation with 11 345-kV and 16 138-kV breakers in breaker-and-a-half arrangements, and remove the 138/69-kV autotransformer
- Construct a second circuit to the existing Temple Pecan Creek – Temple SW 138-kV transmission line with a minimum ratings of 486 MVA, 4.4-mile
- Construct a new Boggy Creek 138/69-kV substation approximately 3.58-mile south of the existing Temple 138-kV substation. Relocated the existing 138/69-kV autotransformer from Temple SW to the new Boggy Creek substation, install seven 138-kV breakers in breaker-and-a-half arrangement, and install two 69-kV breakers in single bus arrangement
- Loop in the existing Bell County SW – Temple SW 138-kV transmission line into the new Boggy Creek substation and loop in the existing Taylor SW – Temple SW 138-kV transmission line into the new Boggy Creek substation
- Construct a new Boggy Creek – Minerva 69-kV transmission line with a minimum ratings of 197, approximately 5.0-mile
 - From the Bobby Creek on the vacant sides of the existing double circuit capable structures of Taylor SW – Temple SW and Poague – Seaton 69-kV transmission lines and connecting the existing Minerva at STR 3/5. Disconnecting the existing Temple SW – Minerva 69-kV transmission line at STR 3/5

(Continued on next slide)

Option 4 – Continued

- Upgrade the existing Belton – Belton Southwest – Harker Heights South 138-kV transmission lines with a minimum ratings of 486 MVA, 20.6-mile
- Upgrade the existing Belton – Nolanville 138-kV transmission lines with a minimum ratings of 486 MVA, 2.1-mile
- Upgrade the existing Temple North-2 – Pepper Creek 138-kV transmission line with a minimum ratings of 486 MVA, 2.2-mile
- Install two blocks of 18.4 MVAR capacitor banks at each of the existing Killeen Taft St., Killeen, and Killeen Ft. Hood 138-kV substations
- Upgrade the existing Nolanville – Harker Heights – Killeen Taft Street – Killeen Elm 138-kV transmission lines with a minimum ratings of 486 MVA, 11.3-mile
- Upgrade the existing Temple Elm Creek – Temple North 138-kV double-circuit transmission line with a minimum ratings of 486 MVA, 0.5-mile per-circuit
- Rebuild the existing Temple SW – Boggy Creek – Bell County 138-kV transmission line, on an existing ROW parallel to the existing Knob Creek – Salado 345-kV line but on separate structure, with a minimum ratings of 614 MVA, 7.7-mile

Option 4 Map



Project Need Seen by ERCOT	
	Thermal Violation
	Aging Infrastructures
	TSP Criteria Violation

Voltage Legend	
	69-kV
	115-kV
	138-kV
	345-kV

Line Legend	
	Existing Line
	Proposed New Line
	Upgrade Existing Line
	Convert Existing Line
	Retire Existing Line

Substation Legend	
	Existing Substation
	New/Convert Substation
	New Transformer



Option 5 – Option 4 with 69-kV to 138-kV Conversion


- Install a second 345/138-kV autotransformer at the existing Temple Pecan Creek substation with 600 MVA rating and loop in the existing Temple SW – Belfalls 345-kV transmission line into Temple Pecan Creek substation
- Install a second 345/138-kV autotransformer at the existing Temple SW substation with 600 MVA rating, and rebuild the existing Temple SW substation with 11 345-kV and 16 138-kV breakers in breaker-and-a-half arrangements, and remove the 138/69-kV autotransformer
- Construct a second circuit to the existing Temple Pecan Creek – Temple SW 138-kV transmission line with a minimum ratings of 486 MVA, 4.4-mile
- Construct a new Boggy Creek 138/69-kV substation approximately 3.58-mile south of the existing Temple 138-kV substation. Relocated the existing 138/69-kV autotransformer from Temple SW to the new Boggy Creek substation, install seven 138-kV breakers in breaker-and-a-half arrangement, and install two 69-kV breakers in single bus arrangement
- Loop in the existing Bell County SW – Temple SW 138-kV transmission line into the new Boggy Creek substation and loop in the existing Taylor SW – Temple SW 138-kV transmission line into the new Boggy Creek substation
- Construct a new Boggy Creek – Minerva 69-kV transmission line with a minimum ratings of 197, approximately 5.0-mile
 - From the Bobby Creek on the vacant sides of the existing double circuit capable structures of Taylor SW – Temple SW and Poague – Seaton 69-kV transmission lines and connecting the existing Minerva at STR 3/5. Disconnecting the existing Temple SW – Minerva 69-kV transmission line at STR 3/5

(Continued on next slide)

Option 5 – Continued

- Upgrade the existing Belton – Belton Southwest – Harker Heights South 138-kV transmission lines with a minimum ratings of 486 MVA, 20.6-mile
- Upgrade the existing Belton – Nolanville 138-kV transmission lines with a minimum ratings of 486 MVA, 2.1-mile
- Upgrade the existing Temple North-2 – Pepper Creek 138-kV transmission line with a minimum ratings of 486 MVA, 2.2-mile
- Install two blocks of 18.4 MVAR capacitor banks at each of the existing Killeen Taft St., Killeen, and Killeen Ft. Hood 138-kV substations
- Upgrade the existing Nolanville – Harker Heights – Killeen Taft Street – Killeen Elm 138-kV transmission lines with a minimum ratings of 486 MVA, 11.3-mile
- Upgrade the existing Temple Elm Creek – Temple North 138-kV double-circuit transmission line with a minimum ratings of 486 MVA, 0.5-mile per-circuit
- Rebuild the existing Temple SW – Boggy Creek – Bell County 138-kV transmission line, on an existing ROW parallel to the existing Knob Creek – Salado 345-kV line but on separate structure, with a minimum ratings of 614 MVA, 7.7-mile
- Upgrade the existing Temple SW – Seaton 138-kV transmission line with a minimum ratings of 486 MVA, 2.7-mile
- Convert the existing Poague 69-kV substation to 138/69-kV substation by installing a new 100 MVA 138/69-kV
- Convert the existing Temple Taylor Valley 69-kV substation to 138-kV substation
- Convert the existing Seaton – Poague – Temple Taylor Valley – Bell County 69-kV transmission lines to 138-kV with a minimum ratings of 486 MVA, 5.9-mile

Option 5 Map



Project Need Seen by ERCOT	
	Thermal Violation
	Aging Infrastructures
	TSP Criteria Violation

Voltage Legend	
	69-kV
	115-kV
	138-kV
	345-kV

Line Legend	
	Existing Line
	Proposed New Line
	Upgrade Existing Line
	Convert Existing Line
	Retire Existing Line

Substation Legend	
	Existing Substation
	New/Convert Substation
	New Transformer



Option 6 – Option 3 with 69-kV to 138-kV Conversion

- Install a second 345/138-kV autotransformer at the existing Temple Pecan Creek substation with 600 MVA rating and loop in the existing Temple SW – Belfalls 345-kV transmission line into Temple Pecan Creek substation
- Install a second 345/138-kV autotransformer at the existing Temple SW substation with 600 MVA rating, and rebuild the existing Temple SW substation with 11 345-kV and 16 138-kV breakers in breaker-and-a-half arrangements, and remove the 138/69-kV autotransformer
- Construct a second circuit to the existing Temple Pecan Creek – Temple SW 138-kV transmission line with a minimum ratings of 486 MVA, 4.4-mile
- Construct a new Boggy Creek 138/69-kV substation approximately 3.58-mile south of the existing Temple 138-kV substation. Relocated the existing 138/69-kV autotransformer from Temple SW to the new Boggy Creek substation, install seven 138-kV breakers in breaker-and-a-half arrangement, and install two 69-kV breakers in single bus arrangement
- Loop in the existing Bell County SW – Temple SW 138-kV transmission line into the new Boggy Creek substation and loop in the existing Taylor SW – Temple SW 138-kV transmission line into the new Boggy Creek substation
- Construct a new Boggy Creek – Minerva 69-kV transmission line with a minimum ratings of 197, approximately 5.0-mile
 - From the Bobby Creek on the vacant sides of the existing double circuit capable structures of Taylor SW – Temple SW and Poague – Seaton 69-kV transmission lines and connecting the existing Minerva at STR 3/5. Disconnecting the existing Temple SW – Minerva 69-kV transmission line at STR 3/5


(Continued on next slide)

Option 6 – Continued

- Upgrade the existing Belton – Belton Southwest – Harker Heights South 138-kV transmission lines with a minimum ratings of 486 MVA, 20.6-mile
- Upgrade the existing Belton – Nolanville 138-kV transmission lines with a minimum ratings of 486 MVA, 2.1-mile
- Upgrade the existing Temple North-2 – Pepper Creek 138-kV transmission line with a minimum ratings of 486 MVA, 2.2-mile
- Install two blocks of 18.4 MVAR capacitor banks at each of the existing Killeen Taft St., Killeen, and Killeen Ft. Hood 138-kV substations
- Upgrade the existing Nolanville – Harker Heights – Killeen Taft Street – Killeen Elm 138-kV transmission lines with a minimum ratings of 486 MVA, 11.3-mile
- Upgrade the existing Temple Elm Creek – Temple North 138-kV double-circuit transmission line with a minimum ratings of 486 MVA, 0.5-mile per-circuit
- Upgrade the existing Temple SW – Seaton 138-kV transmission line with a minimum ratings of 486 MVA, 2.7-mile
- Convert the existing Poague 69-kV substation to 138/69-kV substation by installing a new 100 MVA 138/69-kV
- Convert the existing Temple Taylor Valley 69-kV substation to 138-kV substation
- Convert the existing Seaton – Poague – Temple Taylor Valley – Bell County 69-kV transmission lines to 138-kV with a minimum ratings of 486 MVA, 5.9-mile

(Map on next slide)

Option 6 Map



Project Need Seen by ERCOT	
	Thermal Violation
	Aging Infrastructures
	TSP Criteria Violation

Voltage Legend	
	69-kV
	115-kV
	138-kV
	345-kV

Line Legend	
	Existing Line
	Proposed New Line
	Upgrade Existing Line
	Convert Existing Line
	Retire Existing Line

Substation Legend	
	Existing Substation
	New/Convert Substation
	New Transformer



Option 7

- Install a second 345/138-kV autotransformer at the existing Temple Pecan Creek substation with 600 MVA rating and loop in the existing Temple SW – Belfalls 345-kV transmission line into Temple Pecan Creek substation
- Install a second 345/138-kV autotransformer at the existing Temple SW substation with 600 MVA rating, and rebuild the existing Temple SW substation with 11 345-kV and 16 138-kV breakers in breaker-and-a-half arrangements, and remove the 138/69-kV autotransformer
- Construct a second circuit to the existing Temple Pecan Creek – Temple SW 138-kV transmission line with a minimum ratings of 486 MVA, 4.4-mile
- Construct a new Boggy Creek 138/69-kV substation approximately 3.58-mile south of the existing Temple 138-kV substation. Relocated the existing 138/69-kV autotransformer from Temple SW to the new Boggy Creek substation, install seven 138-kV breakers in breaker-and-a-half arrangement, and install two 69-kV breakers in single bus arrangement
- Loop in the existing Bell County SW – Temple SW 138-kV transmission line into the new Boggy Creek substation and loop in the existing Taylor SW – Temple SW 138-kV transmission line into the new Boggy Creek substation
- Construct a new Boggy Creek – Minerva 69-kV transmission line with a minimum ratings of 197, approximately 5.0-mile
 - From the Bobby Creek on the vacant sides of the existing double circuit capable structures of Taylor SW – Temple SW and Poague – Seaton 69-kV transmission lines and connecting the existing Minerva at STR 3/5. Disconnecting the existing Temple SW – Minerva 69-kV transmission line at STR 3/5


(Continued on next slide)

Option 7

- Upgrade the existing Belton – Belton Southwest – Harker Heights South 138-kV transmission lines with a minimum ratings of 486 MVA, 20.6-mile
- Upgrade the existing Belton – Nolanville 138-kV transmission lines with a minimum ratings of 486 MVA, 2.1-mile
- Upgrade the existing Temple North-2 – Pepper Creek 138-kV transmission line with a minimum ratings of 486 MVA, 2.2-mile
- Install two blocks of 18.4 MVAR capacitor banks at each of the existing Killeen Taft St., Killeen, and Killeen Ft. Hood 138-kV substations
- Upgrade the existing Nolanville – Harker Heights 138-kV transmission lines with a minimum ratings of 486 MVA, 7.0-mile
- Install a new 600 MVA 345/138-kV autotransformer at the existing Salado SW and connect the existing 138-kV and 345-kV
- Construct a new Salado SW – Belton Southwest 138-kV transmission line with a minimum ratings of 486 MVA, approximately 7.4-mile
- Construct a new second circuit to the existing Knob Creek – Salado SW 345-kV transmission line with a minimum ratings of 1912 MVA, 13.8-mile
- Rebuild the existing Temple SW – Boggy Creek – Bell County 138-kV transmission line, on an existing ROW parallel to the existing Knob Creek – Salado 345-kV line but on separate structure, with a minimum ratings of 614 MVA, 7.7-mile
- Upgrade the existing Temple SW – Seaton 138-kV transmission line with a minimum ratings of 486 MVA, 2.7-mile

(Map on next slide)

Option 7 Map



Project Need Seen by ERCOT	
	Thermal Violation
	Aging Infrastructures
	TSP Criteria Violation

Voltage Legend	
	69-kV
	115-kV
	138-kV
	345-kV

Line Legend	
	Existing Line
	Proposed New Line
	Upgrade Existing Line
	Convert Existing Line
	Retire Existing Line

Substation Legend	
	Existing Substation
	New/Convert Substation
	New Transformer



Preliminary Results of Reliability Assessment – Options

Option	N-1		G-1 + N-1		X-1 + N-1	
	Thermal Violations	Voltage Violations	Thermal Violations	Voltage Violations	Thermal Violations	Voltage Violations
Base Case	None	None	None	None	7	31
Option 1	None	None	None	None	6	19
Option 2	2	None	None	None	2	None
Option 3	3	None	None	None	None	None
Option 3 with 345-kV DCKT	2	None	1	None	None	None
Option 4	None	None	None	None	None	None
Option 5	None	None	None	None	None	None
Option 6	1	None	1	None	None	None
Option 7	None	None	None	None	None	None

- Options 4, 5, and 7 were selected for further evaluations

Long-Term Load Serving Capability Evaluation

- Assumptions
 - Adjusted load up in the study area (Bell County), excluding Flexible Loads in the area
 - Adjusted conforming load down outside of study area to balance power
 - Based on N-1 contingency
- Preliminary Findings

Option	Incremental Load Serving Capability (~MW)
Option 4	547
Option 5	542
Option 7	496

Next Steps and Tentative Timeline

- ERCOT will continue to evaluate options and provide status updates at future RPG meetings
 - Planned maintenance outage evaluation
 - Cost estimates and feasibility assessment
- ERCOT may perform the following assessment on the preferred Option
 - Congestion analysis
 - Generation addition and load scaling sensitivity analyses
 - Planning Guide (PG) section 3.1.3 (4)
 - Subsynchronous Resonance (SSR) Assessment
 - Nodal Protocol Section 3.22.1.3(2)
- Tentative timeline
 - Status update at future RPG meetings
 - Final recommendation in Q2 2024

Thank you!



Stakeholder comments also welcomed through:

Tanzila.Ahmed@ercot.com

Robert.Golen@ercot.com