



Permian Basin Reliability Plan Study – Status Update


Ying Li

RPG Meeting
July 16, 2024

Recap: Introduction

- H.B. 5066 (May 2023) requires the PUCT to direct ERCOT to develop a Reliability Plan for the Permian Basin region and that the plan must:
 - Address extending transmission service to areas where mineral resources have been found
 - Address increasing available capacity to meet forecasted load
 - Provide available infrastructure to reduce interconnection times in areas without access to transmission service
- PUCT Order Project No. 55718 (December 2023)
 - Procedural Process and Timeline
 - Not later than July 2024, ERCOT must file a final reliability plan at the Commission in this project, and after opportunity for stakeholder feedback, and Commission will review and approve a reliability plan for the Permian Basin region
 - The applicable transmission service providers (TSPs) responsible for constructing the transmission infrastructure in the Commission-approved reliability plan can then move forward with filing the necessary applications for certificate of convenience and necessity (CCN) at the Commission
- Significant progress has been made to address the high demand growth in the Permian Basin area
 - Delaware Basin Load Integration Study in 2019
 - Permian Basin Load Interconnection Study in 2021


Recap: Procedural Process and Timeline per PUCT Order Project No. 55718




ERCOT Status Update Notifications

- ERCOT presented the draft study scope at January RPG meeting
 - <https://www.ercot.com/calendar/01172024-RPG-Meeting>
- ERCOT presented the updated study scope at February RPG meeting
 - <https://www.ercot.com/calendar/02122024-RPG-Meeting>
- ERCOT presented the status update at March, April, May, and June RPG meetings
 - <https://www.ercot.com/calendar/03182024-RPG-Meeting--Webex>
 - <https://www.ercot.com/calendar/04092024-RPG-Meeting>
 - <https://www.ercot.com/calendar/05142024-RPG-Meeting>
 - <https://www.ercot.com/calendar/06112024-RPG-Meeting>
- ERCOT hosted a Permian Basin Reliability Plan Study workshop on June 28, 2024, for all stakeholders
 - <https://www.ercot.com/calendar/06282024-Permian-Basin-Reliability-Plan>
- ERCOT presented the local transmission upgrades and 345-kV import paths needed to serve all the Permian Basin load for 2030 and 2038
- ERCOT will present the extra high voltage (EHV) import paths options for 2038
- ERCOT will present the cost estimates

Recap: Local Transmission Projects for 2038 to Serve All Loads in Permian Basin Region




Recap: Local Transmission Projects for 2030 to Serve All Loads in Permian Basin Region



Recap: Import Paths – Major Consideration Factors

- Import paths could serve as dual-purpose
 - Import generation to Permian Basin region to serve the forecasted Permian Basin load
 - Export rich renewable generation in West Texas to the load centers
- Generation
 - Import from generation rich area
- CIP-014
 - Avoid voltage instability under the major 345-kV substation outage
- ERCOT Long-Term West Texas Export Study
 - Considered the West Texas export paths if applicable
- Cost effectiveness


Recap: 345-kV Import Paths to Permian Basin Region for 2038



Recap: 345-kV Import Paths to Permian Basin Region for 2038 (cont.)

- Import Path 1
 - Construct a new 345-kV New Substation 2, about 2 miles southeast of the existing Comanche Peak Switch, cutting into the existing Comanche Peak – Wolf Hollow/Mitchell Bend 345-kV double-circuit line and Comanche Peak – Timberview/Johnson 345-kV double-circuit line
 - New New Substation 2 – Comanche Switch 345-kV double-circuit line
 - New New Substation 2 – Central Bluff – Longshore – Rockhound 345-kV double-circuit line
 - New Moss – Border 345-kV double-circuit line
- Import Path 2
 - New Sam Switch – Comanche Switch – Twin Butte – King Mountain 345-kV double-circuit line
- Import Path 3
 - New Bell East – Buckhorn – New Substation 1 – Nevil Road – Lynx 345-kV double-circuit line
 - New Substation 1 is cutting into the existing Big Hill – Twin Butte 345-kV line, about 16 miles away from the Big Hill substation
 - Lynx is cutting into the existing Bakersfield – Solstice 345-kV double-circuit line
- Import Path 4
 - New Fowlerton – Hamilton – Bottlebrush – Solstice 345-kV double-circuit line
 - No 345/138-kV transformers at Hamilton in this study
 - Add new dynamic reactive devices at Hamilton
- Additional Upgrades
 - New White River – Long Draw 345-kV double-circuit line
 - Bypass the series capacitors at Edison and add new dynamic reactive devices

Recap: 345-kV Import Paths to Permian Basin Region for 2030




Recap: 345-kV Import Paths to Permian Basin for 2030 (cont.)

- Portion of Import Path 1
 - Construct a new 345-kV New Substation 2, about 2 miles southeast of the existing Comanche Peak Switch, cutting into the existing Comanche Peak – Wolf Hollow/Mitchell Bend 345-kV double-circuit line and Comanche Peak – Timberview/Johnson 345-kV double-circuit line
 - New New Substation 2 – Comanche Switch 345-kV double-circuit line
 - New Longshore – Rockhound 345-kV double-circuit line
- Import Path 2
 - New Sam Switch – Comanche Switch – Twin Butte – King Mountain 345-kV double-circuit line
- Import Path 4
 - New Fowlerton – Hamilton – Bottlebrush – Solstice 345-kV double-circuit line
 - No 345/138-kV transformers at Hamilton in this study
 - Add new dynamic reactive devices at Hamilton
- Additional Upgrade
 - Bypass the series capacitors at Edison and add new dynamic reactive devices


EHV Import Paths to Permian Basin Region

- Size and locations of the load
- Multiple long 345-kV import paths will be needed to transfer power to Permian Basin region
- EHV import paths
 - Voltage level above 345-kV will make these needed transfers more efficient
 - More cost effective, and require less Right of Way, than 345-kV transmission lines of equal MW capacity
 - 500-kV and 765-kV transmission levels were evaluated for 2038
 - The design of the EHV paths considered the 2024 RTP needs

500-kV Import Paths Option for 2038




765-kV Import Paths Option for 2038



Local Transmission Upgrades for EHV Options in 2038 to Serve All Loads in Permian Basin Region

Compared to 2038 345-kV import option:

1. Include the Bakersfield – Schneeman Draw 345-kV double-circuit line upgrade
2. Include the new Solstice – Bottlebrush 345-kV double-circuit line
3. Backout the Moss – Midland County NW and Telephone Road – Gardendale – Clearfork 345-kV line upgrade and add the second circuits
4. Backout the new King Mountain - Creosote 345-kV double-circuit line
5. Backout the White Baker - Bottlebrush (Century) 138-kV line upgrade
6. Backout the Cowpen – Birds of Prey Tap 138-kV line



Study Assumption – Dynamic Studies

- As mentioned at the May 2024 RPG meeting, ERCOT conducted a limited dynamic stability analysis utilizing the case (year 2038) with all identified import path project modeled (345-kV option and 765-kV option)
- Key Assumptions:
 - Modeled dynamic data of all generation, except certain units (e.g., unit with no dynamic model available)
 - Included representative dynamic load model of the potential large load based on the review of existing load models in the study region
 - Modeled all transmission upgrades identified in the study region, including all dynamic reactive power devices (e.g., synchronous condensers) assumed in the 2038 case
 - Tested contingencies based on the planning criteria in ERCOT Planning Guide Section 4 and NERC TPL-001-5.1
 - 345-kV import paths option: All P1 and P7 345-kV and 138-kV contingencies in the study region
 - 765-kV import paths option: All P1 and P7 345-kV contingencies in the study region as well as the contingencies associated with the 765-kV import paths

Dynamic Studies Findings

- The results of the dynamic stability analysis indicated no dynamic stability issue for the 2038 case with all transmission upgrades relevant to 345-kV import paths as well as 765-kV import paths

Cost Estimates

- Capital costs estimates of each transmission upgrade at 345-kV level or lower were provided by the TSP(s) responsible for each upgrade
 - ERCOT used the cost estimates provided by the TSPs to calculate total project cost estimates for various transmission upgrades
- For EHV (500-kV and 765-kV) options, ERCOT used a general cost estimate to calculate the total project cost estimates
 - Referenced the MISO 2024 Transmission Cost Estimation Guide
 - Link: [20240131_PSC_Item_05_Transmission_Cost_Estimation_Guide_for_MTEP24 - Redline631529.pdf \(misoenergy.org\)](https://www.misoenergy.org/20240131_PSC_Item_05_Transmission_Cost_Estimation_Guide_for_MTEP24_-_Redline631529.pdf)
 - General cost estimates for EHV options

	T-Line \$/mile	Substation	Transformer
500-kV double-circuit	\$6.9M*	\$94.8M	\$15.9M
765-kV single-circuit	\$6.1M	\$97.3M	\$27.2M

*A ratio of 1.4 was used to estimate the cost for 500-kV double-circuit line based on 500-kV single-circuit line

Cost Estimates Summary

- Cost estimates in \$ Billion

	2030	2038		
		345-kV	500-kV	765-kV
Local Upgrades	5.054	5.255	4.712	4.712
Import Paths	3.991	7.694	10.605	9.059
Total	9.045	12.949	15.317	13.771

- The cost estimates of the local upgrades include the 345-kV and 138-kV transmission upgrades, 69-kV transmission conversions, and placeholder reactive devices (capacitor banks)
- The difference of the cost estimates for the local upgrades between 345-kV and EHV import paths are due to certain transmission upgrades not needed in the EHV options
- The cost estimates of the import paths include the 345-kV and EHV transmission upgrades and dynamic reactive devices

Comparison of 345-kV and EHV Import Paths in 2038

	345-kV	500-kV	765-kV
Meets ERCOT and NERC Reliability Criteria	Yes	Yes	Yes
Improves Long-Term Load Serving Capability	Yes	Yes	Yes (Best)
Improves Operational Flexibility	Yes	Yes	Yes
Reduces Transmission Losses	Yes (Least)	Yes	Yes (Best)
Long Distance Transmission Capability	Least	Better	Best
Number of Import Paths Required	5	4	3
Additional Transfer Capability* (MW)	1,340	1,712	2,105
Project Feasibility	Yes	Yes	Yes
New ROW** Required (miles)	1,676	1,370	1,255
Average Transmission Line Cost*** (\$Million/mile)	4.04	6.86	6.10
Cost Estimate (\$Billion)	12.95	15.32	13.77

* Additional transfer capability under N-1 contingency conditions.

** A routing adder of 20% to the straight distance between two end points was assumed.

*** For 345-kV import paths option, the average cost based on the TSPs cost estimates for 345-kV import paths was used. MISO 2024 Transmission Cost Estimation Guide was referenced for the EHV options (500-kV or 765-kV).

Next Step

- Complete the report in July 2024

Deliverables and Timeline

- The study is expected to be completed in June 2024 and the final report is ready in July 2024
- Status updates at RPG meetings
- Tentative Timelines

Deliverables	Tentative Timeline
Load Update by TSPs	January 2024
Review the Data Provided by TSPs	January 2024
Develop Study Base Case and Conduct Reliability Analysis	February 2024
Study Potential Transmission Solutions and Propose Final Reliability Plan	March – June 2024
Final Report	July 2024

Thank you!



Stakeholder comments also welcomed through:

Ying.Li@ercot.com

Robert.Golen@ercot.com

Appendix – Local Transmission Projects for 2030 and 2038 in Delaware Basin Area

- 345-kV
 - Update the Stage 3 upgrade: New 345-kV double-circuit transmission line from Riverton – Drill Hole (instead of new 345-kV single-circuit line from Riverton – Owl Hill)
 - Stage 4 upgrade: Convert the existing Sand Lake – Riverton 138-kV line into 345-kV and add a new 138-kV line from Sand Lake – Riverton
 - Update the Stage 5 upgrade: Faraday – Lamesa – Clearfork – Drill Hole (instead of Riverton)
 - Add a new Border 345/138-kV substation with two 345/138-kV transformers; Loop the Stage 5 upgrade of new Clearfork – Drill Hole 345-kV double-circuit transmission line into the new Border 345-kV station; Add a new Border – Quarry Field 345-kV double-circuit transmission line (2038)
 - Add new 345/138-kV substations with two 345/138-kV transformers each at Culberson, 900005Tap (between Culberson and Sand Lake), and Faulkner
 - Add new 345-kV double-circuit transmission lines to form a loop: Riverton – Drill Hole – Culberson – 900005Tap – Faulkner – Solstice
 - Add a new 345/138-kV Creosote substation with three 345/138-kV transformers and add new 345-kV double-circuit transmission lines from King Mountain to Creosote to Toyah Creek
 - Add a new Fort Stockton Switch 345/138-kV substation with three 345/138-kV transformers; Loop the existing Bakersfield – Solstice 345-kV double-circuit transmission lines into Fort Stockton Switch (2038)
 - Upgrade the existing Bakersfield – Nevill Road – North McCamey 345-kV transmission lines and add second circuits
 - Add new 345/138-kV substations with two 345/138-kV transformers each at White Baker and Century (Bottlebrush) and add new 345-kV double-circuit transmission lines from Bakersfield to White Baker to Bottlebrush

Appendix – Local Transmission Projects for 2030 and 2038 in Delaware Basin Area (cont.)

- 138-kV

- Add Quarry Field to Border 138-kV second circuit and Shifting Sand – Wink 138-kV second circuit, and add new 138-kV double-circuit transmissions line from Border – Shifting Sand to connect and serve the new loads and form a loop
- Add Border – Riverton 138-kV second circuit
- Add new 138-kV double-circuit transmission lines from 900005Tap to Faulkner to connect and serve the new loads and form a loop
- Add new 138-kV transmission lines from Faulkner to Cryo to connect and serve the new loads and form a loop
- Upgrade the existing Bottlebrush (Century) – White Baker – Girvin 138-kV transmission line
- Bypass the Solstice phase shifter transformer and upgrade the existing Solstice – FT Stockton Plant 138-kV transmission line
- Upgrade the existing Cowpen – Birds of Pray Tap 138-kV transmission line (2038)
- Upgrade the existing Creosote - Trans Pecos Tap 138-kV transmission line
- Rebuild the existing Solstice – Hayter Tap 138-kV transmission line to double-circuit; Move the large load as well as LCRA load at Hayter Tap to Hayter; Radially serve the loads at Hayter from Solstice
- Convert the existing 16th Street – FT Stockton – Pinion – Ocotillo 69-kV transmission line to 138kV; Build a 138-kV tie between Ocotillo and Bottlebrush 138-kV substations; and Expand Ocotillo substation and move the 16th Street 138/69-kV transformer to Ocotillo

Appendix – Local Transmission Projects for 2030 and 2038 in Midland Basin Area

- 345-kV
 - Add a new 345/138-kV Prong Moss substation with two new 345/138-kV transformers; Loop the existing Bulldog – Elbow 138-kV transmission line into Prong Moss; Loop the existing Hillcrest – McDonald 138-kV line into Prong Moss; Convert the existing Big Spring – Signal Mountain 69-kV line to 138-kV; and Connect Signal Mountain to Prong Moss
 - Add a new 345/138-kV Roscoe substation near the Sweetwater Tap with two new 345/138-kV transformers; Loop the existing Sweetwater East – Champion and Bitter Creek – Cattleman 345-kV double-circuit line into Roscoe; Convert the existing Plowboy – Escoka 69-kV line to 138-kV; Loop the converted Plowboy – Eskota 138-kV line into Roscoe near the Sweetwater; Move the Eskota 138/69-kV transformer #1 to Plowboy
 - Upgrade the existing 345-kV double-circuit transmission lines from Cattleman to Sweetwater East to Long Creek
 - Upgrade the existing Bluff Creek – Abilene Mulberry Creek 345-kV transmission line and add second circuit
 - Upgrade the existing Moss – Midland County NW and Telephone Road – Gardendale – Clearfork 345-kV transmission lines and add second circuits
 - Upgrade the existing Bakersfield – Cedar Canyon – Noelke – Schneeman Draw 345-kV double-circuit transmission lines (needed for EHV options)

Appendix – Local Transmission Projects for 2030 and 2038 in Midland Basin Area (cont.)

- 138-kV
 - Add a new Ranger (Morgan Creek) – Frontier 138-kV transmission line
 - Upgrade the existing Ranger – Sun – Demott and Ranger – China Groove – Snyder 138-kV transmission lines
 - Upgrade the existing Eiland – Elbow 138-kV transmission line
 - Upgrade the existing Luther – Bulldog 138-kV transmission line
 - Upgrade the existing Natural Dam – Beals Creek 138-kV transmission line
 - Upgrade the existing Big Springs – Steer 138-kV transmission line
 - Upgrade the existing Friend Ranch – Carver 138-kV transmission line
 - Connect the new load bus 900052 to Big Lake to form a 138-kV loop
 - Upgrade the existing Grady – Coronado Midstream Tap – Sales Ranch 138-kV transmission line
 - Upgrade the existing Odessa – Reiter 138-kV double-circuit transmission line
 - Convert the existing Snyder – Scurry – China Grove and Snyder – Amoco Tap – China Grove 69-kV transmission lines to 138-kV
 - Convert the Stanton East – Midland Basin – Spraberry 69-kV transmission line to 138-kV
 - Convert the Illinois #4 – Pandale – Ozona – Friend Ranch 69-kV transmission line to 138-kV, expand Ozona substation and move the Illinois #4 138/69-kV transformer to Ozona
 - Expand the Pandale substation and build a 138-kV tie between Pandale and Stockman substations
 - Convert the Cedar Hill – Sterling City – Chalk 69-kV transmission line to 138-kV
 - Upgrade the existing Oak Creek – Cedar Hills 138-kV transmission line