



TEXAS RE

**NERC Interregional
Transfer Capability Study
Summary
For
ERCOT Supply Analysis Working Group**

**Mark Henry
November 22, 2024**

ITCS Objectives

Congress directed NERC to perform a study of Interregional Transmission Capacity (ITCS) in the Fiscal Responsibility Act of 2023. ITCS aligns with ERO's obligations to perform reliability assessments

Independent and objective

System-wide perspective

Reliability focus

Collaboration and coordination

Strategic planning

Repeatable process



ITCS Scope: Fiscal Responsibility Act of 2023



Part I: Calculate current total transfer capability




Part II: Recommend prudent additions to transfer capability




Part III: Recommend how to meet and maintain transfer capability



ITCS Timeline Overview



Part I Total Import Capabilities as Percentage of Peak Load (Winter)




SUMMER ALSO CALCULATED – ALL NEIGHBORS LOWER

● To be evaluated in Canadian analysis



Part II Prudent Additions Study Approach



What are technically prudent additions to interregional transfer capability?

- *Strengthen reliability*
- *Serve load under extreme conditions*
- *Do not create other reliability problems*



Energy Margin Methodology for Part II: Scope and Limitations

What this method DOES

- ✓ Prioritize regions for interregional transfer capability
- ✓ Tracks daily and hourly availability of all resource types
- ✓ Calculates relative surplus and deficit in each region, at the same time
- ✓ Performs a reliability-only dispatch of resources
- ✓ Allows regions to import from one region while exporting to another
- ✓ Assumes full import capability from neighbors
- ✓ Obtain results driven by extreme weather

What this method DOES NOT

- ✗ Represent actual physical power flows across the network ... not a planning study
- ✗ Track individual resource performance or replace a full energy assessment/LOLE study
- ✗ Calculate relative costs or prices between regions
- ✗ Perform an economic, least-cost (production cost) dispatch
- ✗ Only evaluate “neighbor” flows
- ✗ Evaluate potential import from non-adjacent planning areas (neighbor’s neighbor)
- ✗ Consider probability of extreme conditions



Six-Step Prudent Addition Process

Identify

1. Identify regions that are import constrained during Resource Deficiency hours (region is unable to keep its energy margin above 3%)

Quantify

2. Calculate maximum shortage (MW) during Resource Deficiency hours

Prioritize

**3. Identify constrained interfaces during Tight Margin hours
Scarcity Factor Difference = measures relative resource surplus on the sending end (source) relative to the importing region (sink)**

Allocate

4. Increase all constrained interfaces at ~33% of max shortage (MW),

- Only increase by a portion of the max shortage to capture interactive effects between regions (increase in one interface affects flows across others)
- Increase for each interface proportional to the scarcity factor difference
- Interfaces with relatively high surplus on sending end available during tight margin hours get proportionally larger increase

Iterate


5. Iterate until all resource deficiencies are mitigated, or until improvement stops because there are no available resources on sending end

Finalize

6. Determine “prudent” level after all runs are complete based on resolving shortfalls



Step 1: Identify hours and regions with resource deficiencies



Step 2: Quantify maximum deficiency

Max resource deficiencies by weather year, by region (2033)

Transmission Planning Region	WY2007	WY2008	WY2009	WY2010	WY2011	WY2012	WY2013	WY2019	WY2020	WY2021	WY2022	WY2023	Max Resource Deficiency
Washington	0	0	0	0	0	0	0	0	0	0	0	0	0
Oregon	0	0	0	0	0	0	0	0	0	0	0	0	0
California North	0	0	0	0	0	0	0	0	0	0	3,211	0	3,211
California South	0	0	0	0	0	0	0	0	0	0	0	0	0
Southwest	0	0	0	0	0	0	0	0	0	0	0	0	0
Wasatch Front	0	0	0	0	0	0	0	0	0	0	0	0	0
Front Range	0	0	0	0	0	0	0	0	0	0	0	0	0
ERCOT	1,361	0	0	9,400	0	0	0	8,977	14,853	18,926	14,321	12,108	18,926
SPP-N	0	0	0	0	0	0	0	0	0	155	0	0	155
SPP-S	0	0	0	0	0	0	0	0	0	4,137	0	0	4,137
MISO-W	0	0	0	0	0	0	0	0	0	0	0	0	0
MISO-C	0	0	0	0	0	0	0	0	0	0	0	0	0
MISO-S	0	0	560	0	629	0	0	0	0	0	0	0	629
MISO-E	0	0	0	0	1,676	0	0	0	5,715	979	0	0	5,715
SERC-C	0	0	0	0	0	0	0	0	0	0	0	0	0
SERC-SE	0	0	0	0	0	0	0	0	0	0	0	0	0
SERC-Florida	0	0	1,030	1,152	0	0	0	0	0	0	0	0	1,152
SERC-E	0	0	0	0	0	0	0	0	0	0	5,849	0	5,849
PJM-W	0	0	0	0	0	0	0	0	0	0	0	0	0
PJM-S	0	0	0	0	0	0	0	0	0	0	4,147	0	4,147
PJM-E	0	0	0	0	0	0	0	0	0	0	0	0	0
New York	0	81	0	3,244	1,748	2,631	1,229	0	0	0	0	3,729	3,729
New England	0	0	0	85	0	984	68	0	0	0	0	0	984

Summer

Winter


Dual Season



Step 3: Prioritize constrained interfaces for additions

1. Identify lines importing into deficient regions
2. Consider interfaces that hit their limit during tight margin hours
3. Prioritize interfaces that have relatively more surplus on the sending end.

*Add to both the ac total import interface and dc-only interfaces



Step 4 & 5: Allocate and Iterate until resource deficiencies are resolved


- 1. Initial addition to transfer capability set to 33% of maximum resource deficiency.**
- 2. Allocate across priority interfaces and rerun the energy margin analysis**
- 3. Recalculate remaining resource deficiency**
- 4. Calculate the reduction in deficiency relative to the addition in transfer capability as a measure of efficacy**
- 5. Iterate until all deficiencies are resolved or transfer capability stops helping**
 - Reduce maximum resource deficiency by at least 75% of additional transfer capability, or
 - Reduce resource deficiency by at least 100% of additional transfer capability in at least 4 hours

Why did we iterate?

- **Saturation effects.** As regions start to export more, their energy margins will go down and there will be less to export in the following iteration.
- **Multiplier effects.** Transmission and energy limited resources (Storage and DR) work together.
- **Interactive effects.** Flows between regions will change relative surplus and scarcity



Step 6: Finalize prudent addition recommendations



Part II Deficiencies and Recommended Prudent Additions (Final)

Transmission Planning Region	Weather Years (WY) / Events	Resource Deficiency Hours	Maximum Deficiency (MW)	Additional Transfer Capability (MW)	Interface Additions (MW)
California North*	WY2022 Heat Wave	17	3,211	1,100	Wasatch Front (1,100)
ERCOT*	Winter Storm Uri (WY2021) and nine other events	135	18,926	14,100	Front Range (5,700) MISO-S (4,300) SPP-S (4,100)
SPP-S	Winter Storm Uri (WY2021)	34	4,137	3,700	Front Range (1,200) ERCOT (800) MISO-W (1,700)
MISO-E	WY2020 Heat Wave and two other events	58	5,715	3,000	MISO-W (2,000) PJM-W (1,000)
MISO-S	WY2009 and WY2011 summer events	4	629	600	ERCOT (300) SERC-SE (300)
SERC-E	Winter Storm Elliott (WY2022)	9	5,849	4,100	SERC-C (300) SERC-SE (2,200) PJM-W (1,600)
SERC-Florida	Summer WY2009 and Winter WY2010	6	1,152	1,200	SERC-SE (1,200)
PJM-S	Winter Storm Elliott (WY2022)	20	4,147	2,800	PJM-E (2,800)
New York	WY2023 Heat Wave and seven other events	52	3,729	3,700	PJM-E (1,800) Québec (1,900)
New England	WY2012 Heat Wave and two other events	5	984	700	Québec (400) Maritimes (300)
TOTAL				35,000	

*Not all deficiency hours were resolved in these events



Part III Scope: Meet and Maintain

Mandate calls for:

- “Recommendations to meet and maintain total transfer capability together with such recommended prudent additions to total transfer capability...”


Report will describe general measures and actions needed to achieve and sustain the identified transfer capability and any recommended enhancements.

- Additional Analysis
- Capital & Infrastructure
- Grid Enhancing Technologies
- Markets & Regulatory
- Resource Additions



Considerations When Reviewing the Report

- Wide-area energy margin assessment and scenario development called for consistency in assumptions and approach, rather than individual entity practices.
- Extreme weather (especially Uri-like scenario) drives results; results do not consider probability of occurrence.
- Study uses transfers to resolve deficiencies below a 3% margin, rather than additional internal demand response or generation (beyond 2033 projections).
- Study does not consider costs or economic factors.
- No specific transmission projects are identified, nor are implementation barriers addressed, technical, financial or regulatory.



Interregional Transfer Capability Study (ITCS)



The background of the slide features a blurred Texas state flag on the left and a target with several darts on the right. The darts are clustered in the center of the target, suggesting a focus on a specific point.

Questions?



TEXAS RE

Ensuring electric reliability for Texans